

Tabela regulacji temperatur wody sieciowej

120/80°C

dla MPEC Sp. z o.o. w Lęborku

Temperatura zewnętrzna /°C/	Temperatura zasilania /°C/	Temperatura powrotu /°C/
- 16	120,0	80,0
- 15	120,0	79,8
- 14	120,0	79,6
- 13	119,9	78,3
- 12	117,5	77,1
- 11	115,1	75,8
- 10	112,7	74,6
- 9	110,3	73,3
- 8	107,9	72,0
- 7	105,4	70,7
- 6	103,0	69,3
- 5	100,5	68,0
- 4	98,0	66,7
- 3	95,5	65,3
- 2	93,0	63,9
- 1	90,5	62,5
0	87,9	61,1
+ 1	85,4	59,7
+ 2	82,8	58,2
+ 3	80,1	56,7
+ 4	77,5	55,2
+ 5	75,0	53,7
+ 6	75,0	53,0
+ 7	75,0	53,0
+ 8	75,0	53,0
+ 9	75,0	53,0
+ 10	75,0	53,0
+ 11	75,0	53,0
+ 12	75,0	53,0
+ 13	75,0	53,0
+ 14	75,0	53,0
+ 15	75,0	53,0