

Tabela regulacji temperatur wody instalacyjnej

dla węzłów o parametrach 80/64 °C

MPEC Sp. z o.o. w Lęborku

obowiązuje od 01.03.2022 r.

Temp. zew. [°C]	Temperatura wody zasilającej [°C]	Temperatura wody powrotnej [°C]
1.	2.	3.
+12	45,0	39,0
+11	45,0	39,0
+10	45,0	39,0
+9	45,0	39,0
+8	45,0	39,0
+7	49,0	42,0
+6	49,0	42,0
+5	50,0	43,0
+4	51,5	44,5
+3	53,5	45,0
+2	55,0	46,0
+1	55,5	46,0
0	56,0	46,5
-1	56,5	46,5
-2	57,0	47,0
-3	57,5	47,0
-4	58,0	47,5
-5	58,5	47,5
-6	59,0	48,0
-7	59,5	48,0
-8	60,0	48,5
-9	60,5	48,5
-10	62,0	49,0
-11	63,0	49,0
-12	64,5	49,5
-13	66,0	49,5
-14	67,0	50,0
-15	68,5	50,0
-16	70,0	50,0

Zatwierdził:

DYREKTOR

mgr inż. Mariusz Hejnar