

Tabela regulacji temperatur wody sieciowej

dla MPEC Sp. z o.o. w Lęborku

Temp. zew. [°C]	Temperatura zasilania [°C]	Temperatura powrotu [°C]
1.	2.	3.
+15	70,0	48,0
+14	70,0	48,0
+13	70,0	48,0
+12	70,0	48,0
+11	70,0	48,0
+10	70,0	48,0
+9	70,0	48,0
+8	70,0	48,0
+7	70,0	48,0
+6	70,0	48,0
+5	70,0	48,7
+4	72,5	50,2
+3	72,1	48,7
+2	74,8	50,2
+1	77,4	51,7
0	79,9	53,1
-1	82,5	54,5
-2	85,0	55,9
-3	85,5	55,3
-4	88,0	56,7
-5	90,5	58,0
-6	93,0	59,3
-7	95,4	60,7
-8	97,9	62,0
-9	100,3	63,3
-10	102,7	64,6
-11	105,1	65,8
-12	107,5	67,1
-13	109,9	68,3
-14	110,0	69,6
-15	110,0	69,8
-16	110,0	70,0

Zatwierdził:

DYREKTOR

mgr inż. Mariusz Hejnar